



600  
PSI



Dwg. Ref.	Qty. Per	Item Number	Description	Materials/Remarks
SHELL				
①	1		Shell	Filament wound epoxy/glass composite with retainer groove formed by adhesive-bonded 6061-T6 hd. anod. Al. alloy collar
END PLUG ASSY				
②	2	50479	Bearing Plate	6061-T6 hard anodized Al. alloy
③	2	50481	Sealing Plate	PVC Thermoplastic
④	2	50483	Feed/Conc Port	Type 316 SST
⑤	2	50325	Permeate Port	PVC Thermoplastic
⑥	2	50489	Port Retainer Set	Type 316 SST-2 identical pieces per set
⑦	2	45244	Retaining Ring	Ph 15-7 Mo SST
⑧	2	45317	Plug Seal	Ethylene propylene O-Ring
⑨	4	45299	Port Seal	Ethylene propylene O-Ring
END PLUG INTERLOCK				
⑩	2	50488	Plate Retainer Set	6061-T6 hd. anod. - 3 distinct pieces/set
⑪	6	45109	Buttonhead Screw	18-8 SST with thread lock patch, 1/4-20 UNC
VESSEL SUPPORT				
⑫	2	45058	Saddle	Cast urethane elastomer
⑬	2	50326	Strap	Type 304 SST - PVC cushion
ELEMENT INTERFACE				
⑭	2	* AS REQ.	Adapter	Engineering Thermoplastic
⑮	2	45294	Adapter Seal	Ethylene propylene O-Ring
FOR REFERENCE ONLY				



SECTION THROUGH END CLOSURE

⚠ INTERNAL PORT PRESSURE MUST NOT EXCEED 125 PSI

• DIMENSIONS IN INCHES (MM APPROX)  
• NOT TO BE USED FOR CONSTRUCTION UNLESS CERTIFIED

Shell Length Code	L L.O.A. IN (MM)	S Span IN (MM)	Empty Weight LB (KG)
1	55.0 (1397)	28 - 31 (711-787)	20 (9)
2	95.0 (2413)	51 - 55 (1295-1397)	30 (14)
3	135.0 (3429)	73 - 78 (1854-1981)	40 (18)
4	175.0 (4445)	95 - 101 (2413-2565)	49 (22)
5	215.0 (5461)	117 - 124 (2972-3150)	59 (27)
6	255.0 (6477)	140 - 148 (3556-3759)	69 (31)

**STRUCTURAL GROUP**

ENGR AP 25JUN99	CODELINE MODEL U4B			
QLTY RAU 15JUL99	BRACKISH RO PRESSURE VESSEL			
MRKT DWE 30JUN99	ECO 89799	SHEET 1 OF 1	SIZE B	NUMBER 504001
				REV K

**RATING:**

DESIGN PRESSURE..... 600 PSI at 120°F  
 (4.1 MPa at 49°C)  
 MIN. OPERATING TEMP..... 20°F  
 (-7°C)  
 FACTORY TEST PRESSURE..... 900 PSI  
 (6.2 MPa)  
 BURST PRESSURE..... 3600 PSI  
 (24.8 MPa)

**INTENDED USE**

The CodeLine Model U4B Brackish RO Pressure Vessel is designed for continuous, long-term use as a housing for reverse osmosis membrane elements to desalt typical brackish waters at pressures up to 600 psi. Any make of 4-inch nominal diameter spiral-wound element is easily accommodated; the appropriate interfacing hardware for the element specified is furnished with the vessel.

The CodeLine Model U4B is designed in accordance with the engineering standards of the Boiler and Pressure Vessel Code of the American Society of Mechanical Engineers (ASME Code). At small additional cost, vessels can be inspected during construction by an ASME Authorized Inspector and ASME Code stamped.

The CodeLine Model U4B must be installed, operated and maintained in accordance with the precautions listed, and good industrial practice to assure safe operation over a long service life.

The high performance reinforced plastic shell must be allowed to expand under pressure; undue restraint at support points or piping connections can cause leaks to develop in the shell. The end closure, incorporating close-fitting, interlocking metal components, must be kept dry and free of corrosion; deterioration can lead to catastrophic mechanical failure of the end plug.

Structural Group will assist the purchaser in determining the suitability of this standard vessel for their specific operating conditions. The final determination however, including evaluation of the standard materials of construction for compatibility with the specific corrosive environment, shall be the responsibility of the purchaser. Alternate materials with enhanced corrosion resistance are available on special order.

Specifications subject to change without notice.

**PRECAUTIONS**

- DO... read, understand and follow all instructions; failure to take every precaution will void warranty and may result in vessel failure
- DO... mount shell with drain holes down on horizontal members at central span "S" using compliant vessel supports furnished; tighten holddown straps just snug
- DO... provide overpressure protection for vessel set at not more than 105% of design pressure
- DO... inspect end closures regularly; replace components that have deteriorated and correct causes of corrosion
- DO NOT...make rigid piping connections to ports or clamp vessel in any way that restricts growth of fiberglass shell under pressure; at design pressure  
 ▲DIA = 0.001 in. (0.25mm) and ▲ = 0.2 in. (5mm) for a length code -6 vessel
- DO NOT...hang piping manifolds from ports or use vessel in any way to support other components
- DO NOT...operate vessel at pressures and temperatures in excess of its rating
- DO NOT... operate vessel without both permeate ports internally connected with a complete set of elements and interconnecting hardware
- DO NOT...Operate vessel with permeate port pressure in excess of 125 psi at 120°F(0.9 Mpa at 49°C)
- DO NOT...tolerate leaks or allow end closures to be routinely wetted in any way
- DO NOT... pressurize vessel until double checking to verify that all three segments of Plate Retainer Set are in place and secured by all three screws at both ends.
- DO NOT...work on any component until first verifying that pressure is relieved from the vessel

**NOTE**

5/32 in. hex key required to open and close vessel.


**ORDERING**

Please specify the following:

- VESSEL MODEL NUMBER built from table of options below
- MEMBRANE ELEMENT MAKE AND MODEL NUMBER
- SPECIFIC CONCERNS regarding INTENDED USE and requests for SPECIAL MATERIALS of CONSTRUCTION

A vessel model number specifies a complete assembly less element interface components. The required interface components are furnished with the vessel but are specified separately.

Membrane elements and between-element connectors (interconnectors) are furnished by membrane element manufacturer.



\* OPTIONAL - Consult factory for specifications and pricing

